

CALIBRATION SHEET

C S

OPT-C-200392

CUSTOMER DETAILS

NAME	Oprix Pty Ltd
SITE	Primary Office
ORDER NO	995442

PROCESS DETAILS

SERVICE	Air Conditioning Outlet Temp
LOCATION	Air Conditioning Ducts

ITEM DETAILS

DEVICE	M12 Temp Tx & Sensor	TAG NO	TG99252
MAKE	Omega	MODEL	NT-100-150
SERIAL No.	XX9942		

TEST EQUIPMENT USED

Beamex iii CAL ID 1-001

RESULTS

CHECK POINT %	INPUT Deg C	THEORETICAL mA OUTPUT		ACTUAL mA	MAX % ERROR
0	0	4.00		4.00	0%
25	50	8.00		8.00	0%
50	100	12.00		12.00	0%
75	150	16.00		16.00	0%
100	200	20.00		20.00	0%

- IF ERROR > 1% CONTACT THE SERVICE MANAGER

COMMENTS

--

SIGNATURE		DATE	9/9/2014
-----------	--	------	----------

CUSTOMER		DATE	
----------	--	------	--